



ELECTRICAL SAFETY PROGRAM

CLEAR WORKING SPACE

Minimum Depth of Clear Working Space at Electric Equipment, 600 V or Less

Nominal voltage to ground	Minimum clear distance for condition ^{2 3}					
	Condition A		Condition B		Condition C	
	m	ft	m	ft	m	ft
0-150	0.9	3.0	0.9	3.0	0.9	3.0
151-600	0.9	3.0	1.0	3.5	1.2	4.0

Notes to Table S-1:

¹ Minimum clear distances may be 0.7 m (2.5 ft) for installations built before April 16, 1981.

² Conditions A, B, and C are as follows:

Condition A -- Exposed live parts on one side and no live or grounded parts on the other side of the working space, or exposed live parts on both sides effectively guarded by suitable wood or other insulating material.

Insulated wire or insulated busbars operating at not over 300 volts are not considered live parts.

Condition B -- Exposed live parts on one side and grounded parts on the other side.

Condition C -- Exposed live parts on both sides of the work space (not guarded as provided in Condition A) with the operator between.

³ Working space is not required in back of assemblies such as dead front switches, circuit breakers, and fuses, or no renewable or adjustable parts (such as fuses or

	³					
	Condition A		Condition B		Condition C	
	m	ft	m	ft	m	ft
601-2500 V	0.9	3.0	1.2	4.0	1.5	5.0
2501-9000 V	1.2	4.0	1.5	5.0	1.8	6.0
9001 V-25 kV	1.5	5.0	1.8	6.0	2.8	9.0
Over 25-75 kV ¹	1.8	6.0	2.5	8.0	3.0	10.0
Above 75 kV ¹	2.5	8.0	3.0	10.0	3.7	12.0

Notes to Table S-2:

¹ Minimum depth of clear working space in front of electric equipment with a nominal voltage to ground above 25,000 volts may be the same as that for 25,000 volts under Conditions A, B, and C for installations built before April 16, 1981.

² Conditions A, B, and C are as follows:

Condition A -- Exposed live parts on one side and no live or grounded parts on the other side of the working space, or exposed live parts on both sides effectively guarded by suitable wood or other insulating material.

Insulated wire or insulated busbars operating at not over 300 volts are not considered live parts.

Condition B -- Exposed live parts on one side and grounded parts on the other side. Concrete, brick, and tile walls are considered as grounded surfaces.

Condition C -- Exposed