Facilities Design Standards

Division 07- Applied Fireproofing

Revision Date: 07/28/2021

1. Design Criteria:

a.

Facilities Design Standards

Revision Date: 07/28/2021

- b. Do not apply fireproofing until clips, hangers, supports, sleeves, and other items that would penetrate the fireproofing are in place.
- c. Defer installing ducts, piping, and other items that would interfere with applying fireproofing until after fireproofing application is complete.
- d. Defer installation of fireproofing on metal decks until placement of concrete above, and/or roofing, if any, has been completed.
- e. Test areas in successive stages. Do not apply fireproofing in the next area until the testing of the first area indicates meeting design requirements.
- f. Protect fireproofing from damage resulting from construction operations or other causes.
- g. Do not expose fireproofing to normally occupied locations. Provide finish surface (GWB assembly or alternative) around exposed areas below ceiling height.

5. <u>Warranties:</u>

- a. Manufacturer's standard product warranty
- b. Installer's standard 1 year warranty on installation of the product.