



Revision Date: 11/10/2023

---

- i. Sign to be "V" shape type providing 180-degree visibility
- ii. Exemplar signage:



- d. Owner furnished and Owner installed items:
    - i. Barcode labels (installed by UVM Physical Plant Department Life Safety Systems office).
  - e. Contractor furnished and installed items:
    - i. Fire extinguisher cabinet
    - ii. Cabinet location signage
    - iii. Fire extinguishers
6. \_\_\_\_\_
- a. Provide installer's typical one-year installation warranty.