

RevisiorDate:2/21/2024

1. Design Criteria
 - a. Refer to Products, Materials and Equipment.
 - b. Reference Standards: To be specified by Design Professional

2. Submittals to be reviewed by University
 - a. Manufacturer's tag shall

RevisiorDate:2/21/2024

- d. The final grading of the topsoil prior to hydroseeding shall be to a tolerance that will not allow ponding water.
- e. Starter fertilizer shall be applied at the manufacturer's suggested rate at the time of seeding.
- f. Watering is to be done by the contractor and is to last for the duration of the warranty period. The Contractor is required to supply all components necessary to complete the job such as sprinklers, hoses, etc. Filling of water tanks to be coordinated with the Grounds Department.
- g. All seeded areas shall be staked to deter foot traffic and maintained by the contractor, using 1" x 1" wooden grade stakes, maximum of 10' o.c., connected with twine with flagging material attached for visibility. The staking shall be maintained through the warranty period.
- h.